

Civil Surgeon Office Tarn Taran

No.CSTT 412

Date: 6/9/24

To Whom It May Concern

This is to certify that we have inspected Guru Amar Dass  
Adarsh Institute, Tarn Taran. After inspecting their Toilets, and other  
rooms, we can certify that their Cleanliness and sanitation is good. Their water is  
Potable through RO system as per report of Rural Water Supply and Sanitation  
Department. This certificate is valid for one year from the date of issue. No Health  
Hazard is seen in the premises of the school. There are separate washroom for girls  
and boys.

  
**District Epidemiologist**  
**TARN TARAN**  
District Epidemiologist

Tarn Taran



# DISTRICT WATER TESTING LABORATORY, TARN TARAN

Village Kakka Kandiala, Block -Tarn Taran District -Tarn Taran.

dwtl11@gmail.com



TC-14756

## TEST REPORT

Name & Address of Customer : <b>GURU AMAR DASS ADARSH INSTITUTE</b> Goindwal Sahib , Tarn Taran		Customer Reference No.	No : 04/01 Dated : 01/04/2025
		Sample Submitted by	Mr. Happy
		Date of Sample Receipt	01/04/2025
		Analysis Starting Date	01/04/2025
		Analysis completion Date	02/04/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC147562500000101F	Sample Type :	Treated Water
Test Report No.:	DWTLTT/2526/00002	Date of Issue :	02/04/2025
Registration no.:	DWTLTT/REG2526/00002	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	1000 ml / Plastic Bottles
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	NA / NA
Village :	Goindwal Sahib	Habitation :	Goindwal Sahib
Block:	Khadoor Sahib	District :	Tarn Taran
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.30@25°C	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	116	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	0.09@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO <sub>3</sub> )	84	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO <sub>3</sub> )	80	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	27.25	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	2.92	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	9.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. \* Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

Reviewed and Approved By

Mr.Mohammad Naushad Alam  
Quality Manager  
Authorized Signatory  
For,District Water Testing Laboratory  
Tarn Taran

End of the Test Report